



OIML Certificate of Conformity

OIML Member State
The Netherlands

Number R60/2000-NL1-15.07 revision 1
Project number 15200054
Page 1 of 3

Issuing authority	NMi Certin B.V. Person responsible: C. Oosterman
Applicant	Anyload Transducer Co. Ltd. #102, 6994 Greenwood Street V5A1X8 Burnaby, BC Canada
Manufacturer	Anyload Youngzon Transducer (Hangzhou) Co. Ltd. Hangzhou Economic & Technological Development Zone No.160, South No.11 Street, 310018 Zhejiang, Hangzhou P.R. China
Identification of the certified type	A single point load cell , with strain gauges Type : 651HSxx, 651KSxx, 651TS, 651JS
Characteristics	See next page

This Certificate attests the conformity of the above identified Type (represented by the sample(s) identified in the OIML Test Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

OIML R60 - Edition 2000 (E) for accuracy class C

This Certificate relates only to the metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML International Recommendation above-identified.
This Certificate does not bestow any form of legal international approval.

Important note: Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate was issued, partial quotation of the Certificate and of the associated OIML Test Report(s) is not permitted, although either may be reproduced in full.

Issuing Authority **NMi Certin B.V., OIML Issuing Authority NL1**
8 October 2015



C. Oosterman
Head Certification Board

NMi Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
the Netherlands
T +31 78 6332332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The notification of NMi Certin B.V. as Issuing Authority can be verified at www.oiml.org

Parties concerned can lodge objection against this decision, within six weeks after the date of submission, to the general manager of NMi (see www.nmi.nl).



The conformity was established by the results of tests and examinations provided in the associated OIML Test Report(s):

- No. NMI-15200054-01 rev. 1 dated 2 October 2015 that includes 51 pages;
- No. NMI-15200054-02 dated 25 June 2015 that includes 46 pages.

Characteristics of the load cell:

Maximum capacity (E_{max})	10 kg up to 100 kg	100 kg up to and including 500 kg
Minimum dead load	0 kg	
Accuracy Class	C	
Rated Output	2,0 mV/V	
Maximum number of load cell intervals (n)	9000	4000
Ratio of minimum LC Verification interval $Y = E_{max} / V_{min}$	18000	26000
Ratio of minimum dead load output return $Z = E_{max} / (2 * DR)$	9000	4000
Input impedance	400 $\Omega \pm 50 \Omega$ or 1100 $\Omega \pm 50 \Omega$	
Temperature range	- 10 °C / + 40 °C	
Fraction p_{LC}	0,7	
Humidity Class	CH	
Safe overload	150 % of E_{max}	
Output impedance	350 $\Omega \pm 10 \Omega$ or 1000 $\Omega \pm 10 \Omega$	
Recommended excitation	10 V AC / DC	
Excitation maximum	15 V AC / DC	
Transducer material	Stainless steel	
Atmospheric protection	Weld sealed	

The characteristics for n_{max} and Y can be reduced separately. Z is proportional or equal to n_{max} .

Each produced load cell is provided with an accompanying document with information about its characteristics.

The above identified Type (represented by the sample(s) identified in the OIML Test Report) have been found to comply with the additional national requirements established by the United States of America (NIST Handbook 44 and NCWM Publication 14), included in the MAA Declaration of Mutual Confidence:

- R 60 DoMC-01 rev.0, Additional requirements from the United States;
- R 60 DoMC-02 rev.0, Additional requirements from the United States.



OIML Certificate of Conformity

OIML Member State
The Netherlands

Number R60/2000-NL1-15.07 revision 1
Project number 15200054
Page 3 of 3

Revision History

This revision replaces the previous version.

Revision	Date	Change(s)
Initial	26 June 2015	-
1	8 October 2015	Corrected errors in the OIML Test Report.